

AENOR

AENOR Product Certificate Low Voltage Material



030/001662

AENOR certifies that the organization

GEWISS, S.P.A.

registered office	VIA ALESSANDRO VOLTA, 1 24069 CENATE SOTTO (Italia)
supplies	Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses(RCBO's)
in compliance with	UNE-EN 61009-1:2006 (EN 61009-1:2004) UNE-EN 61009-1:2006 CORR:2007 (EN 61009-1:2004 CORR:2006) UNE-EN 61009-1:2006/A11:2008 (EN 61009-1:2004/A11:2008) UNE-EN 61009-1:2006/A12:2009 (EN 61009-1:2004/A12:2009) UNE-EN 61009-1:2006/A13:2009 (EN 61009-1:2004/A13:2009) UNE-EN 61009-1:2006/A14:2013 (EN 61009-1:2004/A14:2012; EN 61009-1:2004/A14:2012/AC:2012) UNE-EN 61009-2-1/A11:1999 (EN 61009-2-1/A11:1998) UNE-EN 61009-2-1:1996 (EN 61009-2-1:1994)
References	Specified in Annex to the Certificate
Production site	ZONA INDUSTRIAL 2ª FASE - BUSTELO P 4560-709 PENAFIEL (Portugal)
Certification scheme	In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 030.15.

This certificate supersedes 030/001662, dated 2015-07-14

First issued on	2002-05-17
Modified on	2017-12-14
Validity date	2020-07-14


Rafael GARCÍA MEIRO
Chief Executive Officer

Original Electronic Certificate

AENOR

AENOR Product Certificate Low Voltage Material

030/001662

Annex to Certificate

Trade mark: GEWISS

Type Ref.	No. of poles	Rated current	Rated voltage	Rated residual operating current	Rated short-circuit capacity	Rated residual making and breaking capacity	Tripping	Type	Energy limiting class	Additional information
GW94005	1P+N	6 A	230 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94006	1P+N	10 A	230 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94007	1P+N	16 A	230 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94008	1P+N	20 A	230 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94009	1P+N	25 A	230 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94010	1P+N	32 A	230 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94011	1P+N	13 A	230 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94015	1P+N	6 A	230 V-	300 mA	4500 A	4500 A	C	AC	1	(1)
GW94016	1P+N	10 A	230 V-	300 mA	4500 A	4500 A	C	AC	1	(1)
GW94017	1P+N	16 A	230 V-	300 mA	4500 A	4500 A	C	AC	1	(1)
GW94018	1P+N	20 A	230 V-	300 mA	4500 A	4500 A	C	AC	1	(1)
GW94019	1P+N	25 A	230 V-	300 mA	4500 A	4500 A	C	AC	1	(1)
GW94020	1P+N	32 A	230 V-	300 mA	4500 A	4500 A	C	AC	1	(1)
GW94025	2P	6 A	230 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94026	2P	10 A	230 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94027	2P	16 A	230 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94028	2P	20 A	230 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94029	2P	25 A	230 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94030	2P	32 A	230 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94031	2P	13 A	400 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94035	2P	6 A	230 V-	300 mA	4500 A	4500 A	C	AC	1	(1)
GW94036	2P	10 A	230 V-	300 mA	4500 A	4500 A	C	AC	1	(1)
GW94037	2P	16 A	230 V-	300 mA	4500 A	4500 A	C	AC	1	(1)
GW94038	2P	20 A	230 V-	300 mA	4500 A	4500 A	C	AC	1	(1)
GW94039	2P	25 A	230 V-	300 mA	4500 A	4500 A	C	AC	1	(1)
GW94040	2P	32 A	230 V-	300 mA	4500 A	4500 A	C	AC	1	(1)

First issued on 2002-05-17
Modified on 2017-12-14
Validity date 2020-07-14

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate Low Voltage Material

030/001662

Annex to Certificate

Type Ref.	No. of poles	Rated current	Rated voltage	Rated residual operating current	Rated short-circuit capacity	Rated residual making and breaking capacity	Tripping	Type	Energy limiting class	Additional information
GW94045	3P	6 A	230/400 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94046	3P	10 A	230/400 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94047	3P	16 A	230/400 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94048	3P	20 A	230/400 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94049	3P	25 A	230/400 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94050	3P	32 A	230/400 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94051	3P	13 A	230/400 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94055	3P	6 A	230/400 V-	300 mA	4500 A	4500 A	C	AC	1	(1)
GW94056	3P	10 A	230/400 V-	300 mA	4500 A	4500 A	C	AC	1	(1)
GW94057	3P	16 A	230/400 V-	300 mA	4500 A	4500 A	C	AC	1	(1)
GW94058	3P	20 A	230/400 V-	300 mA	4500 A	4500 A	C	AC	1	(1)
GW94059	3P	25 A	230/400 V-	300 mA	4500 A	4500 A	C	AC	1	(1)
GW94060	3P	32 A	230/400 V-	300 mA	4500 A	4500 A	C	AC	1	(1)
GW94065	4P	6 A	230/400 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94066	4P	10 A	230/400 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94067	4P	16 A	230/400 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94068	4P	20 A	230/400 V-	30 mA	4500 A	4500 A	C	AC	1	(1)

First issued on 2002-05-17
Modified on 2017-12-14
Validity date 2020-07-14

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate Low Voltage Material

030/001662

Annex to Certificate

Type Ref.	No. of poles	Rated current	Rated voltage	Rated residual operating current	Rated short-circuit capacity	Rated residual making and breaking capacity	Tripping	Type	Energy limiting class	Additional information
GW94069	4P	25 A	230/400 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94070	4P	32 A	230/400 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94071	4P	13 A	230/400 V-	30 mA	4500 A	4500 A	C	AC	1	(1)
GW94075	4P	6 A	230/400 V-	300 mA	4500 A	4500 A	C	AC	1	(1)
GW94076	4P	10 A	230/400 V-	300 mA	4500 A	4500 A	C	AC	1	(1)
GW94077	4P	16 A	230/400 V-	300 mA	4500 A	4500 A	C	AC	1	(1)
GW94078	4P	20 A	230/400 V-	300 mA	4500 A	4500 A	C	AC	1	(1)
GW94079	4P	25 A	230/400 V-	300 mA	4500 A	4500 A	C	AC	1	(1)
GW94080	4P	32 A	230/400 V-	300 mA	4500 A	4500 A	C	AC	1	(1)
GW94105	1P+N	6 A	230 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94106	1P+N	10 A	230 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94107	1P+N	16 A	230 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94108	1P+N	20 A	230 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94109	1P+N	25 A	230 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94110	1P+N	32 A	230 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94111	1P+N	13 A	230 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94115	1P+N	6 A	230 V-	300 mA	6000 A	6000 A	C	AC	1	(1)
GW94116	1P+N	10 A	230 V-	300 mA	6000 A	6000 A	C	AC	1	(1)
GW94117	1P+N	16 A	230 V-	300 mA	6000 A	6000 A	C	AC	1	(1)
GW94118	1P+N	20 A	230 V-	300 mA	6000 A	6000 A	C	AC	1	(1)
GW94119	1P+N	25 A	230 V-	300 mA	6000 A	6000 A	C	AC	1	(1)
GW94120	1P+N	32 A	230 V-	300 mA	6000 A	6000 A	C	AC	1	(1)

First issued on 2002-05-17
Modified on 2017-12-14
Validity date 2020-07-14

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate Low Voltage Material

030/001662

Annex to Certificate

Type Ref.	No. of poles	Rated current	Rated voltage	Rated residual operating current	Rated short-circuit capacity	Rated residual making and breaking capacity	Tripping	Type	Energy limiting class	Additional information
GW94125	2P	6 A	230 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94126	2P	10 A	230 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94127	2P	16 A	230 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94128	2P	20 A	230 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94129	2P	25 A	230 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94130	2P	32 A	230 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94131	2P	13 A	400 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94135	2P	6 A	230 V-	300 mA	6000 A	6000 A	C	AC	1	(1)
GW94136	2P	10 A	230 V-	300 mA	6000 A	6000 A	C	AC	1	(1)
GW94137	2P	16 A	230 V-	300 mA	6000 A	6000 A	C	AC	1	(1)
GW94138	2P	20 A	230 V-	300 mA	6000 A	6000 A	C	AC	1	(1)
GW94139	2P	25 A	230 V-	300 mA	6000 A	6000 A	C	AC	1	(1)
GW94140	2P	32 A	230 V-	300 mA	6000 A	6000 A	C	AC	1	(1)
GW94145	3P	6 A	230/400 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94146	3P	10 A	230/400 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94147	3P	16 A	230/400 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94148	3P	20 A	230/400 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94149	3P	25 A	230/400 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94150	3P	32 A	230/400 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94151	3P	13 A	230/400 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94155	3P	6 A	230/400 V-	300 mA	6000 A	6000 A	C	AC	1	(1)
GW94156	3P	10 A	230/400 V-	300 mA	6000 A	6000 A	C	AC	1	(1)

First issued on 2002-05-17
Modified on 2017-12-14
Validity date 2020-07-14

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate Low Voltage Material

030/001662

Annex to Certificate

Type Ref.	No. of poles	Rated current	Rated voltage	Rated residual operating current	Rated short-circuit capacity	Rated residual making and breaking capacity	Tripping	Type	Energy limiting class	Additional information
GW94157	3P	16 A	230/400 V-	300 mA	6000 A	6000 A	C	AC	1	(1)
GW94158	3P	20 A	230/400 V-	300 mA	6000 A	6000 A	C	AC	1	(1)
GW94159	3P	25 A	230/400 V-	300 mA	6000 A	6000 A	C	AC	1	(1)
GW94160	3P	32 A	230/400 V-	300 mA	6000 A	6000 A	C	AC	1	(1)
GW94165	4P	6 A	230/400 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94166	4P	10 A	230/400 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94167	4P	16 A	230/400 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94168	4P	20 A	230/400 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94169	4P	25 A	230/400 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94170	4P	32 A	230/400 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94171	4P	13 A	230/400 V-	30 mA	6000 A	6000 A	C	AC	1	(1)
GW94175	4P	6 A	230/400 V-	300 mA	6000 A	6000 A	C	AC	1	(1)
GW94176	4P	10 A	230/400 V-	300 mA	6000 A	6000 A	C	AC	1	(1)
GW94177	4P	16 A	230/400 V-	300 mA	6000 A	6000 A	C	AC	1	(1)
GW94178	4P	20 A	230/400 V-	300 mA	6000 A	6000 A	C	AC	1	(1)
GW94179	4P	25 A	230/400 V-	300 mA	6000 A	6000 A	C	AC	1	(1)
GW94180	4P	32 A	230/400 V-	300 mA	6000 A	6000 A	C	AC	1	(1)
GW94205	1P+N	6 A	230 V-	30 mA	4500 A	4500 A	C	A	1	(1)

First issued on 2002-05-17
Modified on 2017-12-14
Validity date 2020-07-14

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate Low Voltage Material

030/001662

Annex to Certificate

Type Ref.	No. of poles	Rated current	Rated voltage	Rated residual operating current	Rated short-circuit capacity	Rated residual making and breaking capacity	Tripping	Type	Energy limiting class	Additional information
GW94206	1P+N	10 A	230 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94207	1P+N	16 A	230 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94208	1P+N	20 A	230 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94209	1P+N	25 A	230 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94210	1P+N	32 A	230 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94211	1P+N	13 A	230 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94215	1P+N	6 A	230 V-	300 mA	4500 A	4500 A	C	A	1	(1)
GW94216	1P+N	10 A	230 V-	300 mA	4500 A	4500 A	C	A	1	(1)
GW94217	1P+N	16 A	230 V-	300 mA	4500 A	4500 A	C	A	1	(1)
GW94218	1P+N	20 A	230 V-	300 mA	4500 A	4500 A	C	A	1	(1)
GW94219	1P+N	25 A	230 V-	300 mA	4500 A	4500 A	C	A	1	(1)
GW94220	1P+N	32 A	230 V-	300 mA	4500 A	4500 A	C	A	1	(1)
GW94225	2P	6 A	230 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94226	2P	10 A	230 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94227	2P	16 A	230 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94228	2P	20 A	230 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94229	2P	25 A	230 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94230	2P	32 A	230 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94231	2P	13 A	230/400 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94235	2P	6 A	230 V-	300 mA	4500 A	4500 A	C	A	1	(1)
GW94236	2P	10 A	230 V-	300 mA	4500 A	4500 A	C	A	1	(1)
GW94237	2P	16 A	230 V-	300 mA	4500 A	4500 A	C	A	1	(1)
GW94238	2P	20 A	230 V-	300 mA	4500 A	4500 A	C	A	1	(1)
GW94239	2P	25 A	230 V-	300 mA	4500 A	4500 A	C	A	1	(1)
GW94240	2P	32 A	230 V-	300 mA	4500 A	4500 A	C	A	1	(1)
GW94245	3P	6 A	230/400 V-	30 mA	4500 A	4500 A	C	A	1	(1)

First issued on 2002-05-17
Modified on 2017-12-14
Validity date 2020-07-14

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate Low Voltage Material

030/001662

Annex to Certificate

Type Ref.	No. of poles	Rated current	Rated voltage	Rated residual operating current	Rated short-circuit capacity	Rated residual making and breaking capacity	Tripping	Type	Energy limiting class	Additional information
GW94246	3P	10 A	230/400 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94247	3P	16 A	230/400 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94248	3P	20 A	230/400 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94249	3P	25 A	230/400 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94250	3P	32 A	230/400 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94251	3P	13 A	230/400 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94255	3P	6 A	230/400 V-	300 mA	4500 A	4500 A	C	A	1	(1)
GW94256	3P	10 A	230/400 V-	300 mA	4500 A	4500 A	C	A	1	(1)
GW94257	3P	16 A	230/400 V-	300 mA	4500 A	4500 A	C	A	1	(1)
GW94258	3P	20 A	230/400 V-	300 mA	4500 A	4500 A	C	A	1	(1)
GW94259	3P	25 A	230/400 V-	300 mA	4500 A	4500 A	C	A	1	(1)
GW94260	3P	32 A	230/400 V-	300 mA	4500 A	4500 A	C	A	1	(1)
GW94265	4P	6 A	230/400 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94266	4P	10 A	230/400 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94267	4P	16 A	230/400 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94268	4P	20 A	230/400 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94269	4P	25 A	230/400 V-	30 mA	4500 A	4500 A	C	A	1	(1)

First issued on 2002-05-17
Modified on 2017-12-14
Validity date 2020-07-14

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate Low Voltage Material

030/001662

Annex to Certificate

Type Ref.	No. of poles	Rated current	Rated voltage	Rated residual operating current	Rated short-circuit capacity	Rated residual making and breaking capacity	Tripping	Type	Energy limiting class	Additional information
GW94270	4P	32 A	230/400 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94271	4P	13 A	230/400 V-	30 mA	4500 A	4500 A	C	A	1	(1)
GW94275	4P	6 A	230/400 V-	300 mA	4500 A	4500 A	C	A	1	(1)
GW94276	4P	10 A	230/400 V-	300 mA	4500 A	4500 A	C	A	1	(1)
GW94277	4P	16 A	230/400 V-	300 mA	4500 A	4500 A	C	A	1	(1)
GW94278	4P	20 A	230/400 V-	300 mA	4500 A	4500 A	C	A	1	(1)
GW94279	4P	25 A	230/400 V-	300 mA	4500 A	4500 A	C	A	1	(1)
GW94280	4P	32 A	230/400 V-	300 mA	4500 A	4500 A	C	A	1	(1)
GW94305	1P+N	6 A	230 V-	30 mA	6000 A	6000 A	C	A	3	(1)
GW94306	1P+N	10 A	230 V-	30 mA	6000 A	6000 A	C	A	3	(1)
GW94307	1P+N	16 A	230 V-	30 mA	6000 A	6000 A	C	A	3	(1)
GW94308	1P+N	20 A	230 V-	30 mA	6000 A	6000 A	C	A	3	(1)
GW94309	1P+N	25 A	230 V-	30 mA	6000 A	6000 A	C	A	3	(1)
GW94310	1P+N	32 A	230 V-	30 mA	6000 A	6000 A	C	A	3	(1)
GW94311	1P+N	13 A	230 V-	30 mA	6000 A	6000 A	C	A	1	(1)
GW94315	1P+N	6 A	230 V-	300 mA	6000 A	6000 A	C	A	3	(1)
GW94316	1P+N	10 A	230 V-	300 mA	6000 A	6000 A	C	A	3	(1)
GW94317	1P+N	16 A	230 V-	300 mA	6000 A	6000 A	C	A	3	(1)
GW94318	1P+N	20 A	230 V-	300 mA	6000 A	6000 A	C	A	3	(1)
GW94319	1P+N	25 A	230 V-	300 mA	6000 A	6000 A	C	A	3	(1)
GW94320	1P+N	32 A	230 V-	300 mA	6000 A	6000 A	C	A	3	(1)
GW94325	2P	6 A	230 V-	30 mA	6000 A	6000 A	C	A	1	(1)
GW94326	2P	10 A	230 V-	30 mA	6000 A	6000 A	C	A	1	(1)

First issued on 2002-05-17
Modified on 2017-12-14
Validity date 2020-07-14

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Original Electronic Certificate

AENOR

AENOR Product Certificate Low Voltage Material

030/001662

Annex to Certificate

Type Ref.	No. of poles	Rated current	Rated voltage	Rated residual operating current	Rated short-circuit capacity	Rated residual making and breaking capacity	Tripping	Type	Energy limiting class	Additional information
GW94327	2P	16 A	230 V-	30 mA	6000 A	6000 A	C	A	1	(1)
GW94328	2P	20 A	230 V-	30 mA	6000 A	6000 A	C	A	1	(1)
GW94329	2P	25 A	230 V-	30 mA	6000 A	6000 A	C	A	1	(1)
GW94330	2P	32 A	230 V-	30 mA	6000 A	6000 A	C	A	1	(1)
GW94331	2P	13 A	400 V-	30 mA	6000 A	6000 A	C	A	1	(1)
GW94335	2P	6 A	230 V-	300 mA	6000 A	6000 A	C	A	1	(1)
GW94336	2P	10 A	230 V-	300 mA	6000 A	6000 A	C	A	1	(1)
GW94337	2P	16 A	230 V-	300 mA	6000 A	6000 A	C	A	1	(1)
GW94338	2P	20 A	230 V-	300 mA	6000 A	6000 A	C	A	1	(1)
GW94339	2P	25 A	230 V-	300 mA	6000 A	6000 A	C	A	1	(1)
GW94340	2P	32 A	230 V-	300 mA	6000 A	6000 A	C	A	1	(1)
GW94345	3P	6 A	230/400 V-	30 mA	6000 A	6000 A	C	A	1	(1)
GW94346	3P	10 A	230/400 V-	30 mA	6000 A	6000 A	C	A	1	(1)
GW94347	3P	16 A	230/400 V-	30 mA	6000 A	6000 A	C	A	1	(1)
GW94348	3P	20 A	230/400 V-	30 mA	6000 A	6000 A	C	A	1	(1)
GW94349	3P	25 A	230/400 V-	30 mA	6000 A	6000 A	C	A	1	(1)
GW94350	3P	32 A	230/400 V-	30 mA	6000 A	6000 A	C	A	1	(1)
GW94351	3P	13 A	230/400 V-	30 mA	6000 A	6000 A	C	A	1	(1)
GW94355	3P	6 A	230/400 V-	300 mA	6000 A	6000 A	C	A	1	(1)
GW94356	3P	10 A	230/400 V-	300 mA	6000 A	6000 A	C	A	1	(1)
GW94357	3P	16 A	230/400 V-	300 mA	6000 A	6000 A	C	A	1	(1)

First issued on 2002-05-17
Modified on 2017-12-14
Validity date 2020-07-14

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate Low Voltage Material

030/001662

Annex to Certificate

Type Ref.	No. of poles	Rated current	Rated voltage	Rated residual operating current	Rated short-circuit capacity	Rated residual making and breaking capacity	Tripping	Type	Energy limiting class	Additional information
GW94358	3P	20 A	230/400 V-	300 mA	6000 A	6000 A	C	A	1	(1)
GW94359	3P	25 A	230/400 V-	300 mA	6000 A	6000 A	C	A	1	(1)
GW94360	3P	32 A	230/400 V-	300 mA	6000 A	6000 A	C	A	1	(1)
GW94365	4P	6 A	230/400 V-	30 mA	6000 A	6000 A	C	A	1	(1)
GW94366	4P	10 A	230/400 V-	30 mA	6000 A	6000 A	C	A	1	(1)
GW94367	4P	16 A	230/400 V-	30 mA	6000 A	6000 A	C	A	1	(1)
GW94368	4P	20 A	230/400 V-	30 mA	6000 A	6000 A	C	A	1	(1)
GW94369	4P	25 A	230/400 V-	30 mA	6000 A	6000 A	C	A	1	(1)
GW94370	4P	32 A	230/400 V-	30 mA	6000 A	6000 A	C	A	1	(1)
GW94371	4P	13 A	230/400 V-	30 mA	6000 A	6000 A	C	A	1	(1)
GW94375	4P	6 A	230/400 V-	300 mA	6000 A	6000 A	C	A	1	(1)
GW94376	4P	10 A	230/400 V-	300 mA	6000 A	6000 A	C	A	1	(1)
GW94377	4P	16 A	230/400 V-	300 mA	6000 A	6000 A	C	A	1	(1)
GW94378	4P	20 A	230/400 V-	300 mA	6000 A	6000 A	C	A	1	(1)
GW94379	4P	25 A	230/400 V-	300 mA	6000 A	6000 A	C	A	1	(1)
GW94380	4P	32 A	230/400 V-	300 mA	6000 A	6000 A	C	A	1	(1)
GW95105	1P+N	6A	230 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95106	1P+N	10A	230 V-	30 mA	6000 A	6000 A	B	A	1	(1)

First issued on 2002-05-17
Modified on 2017-12-14
Validity date 2020-07-14

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Original Electronic Certificate

AENOR

AENOR Product Certificate Low Voltage Material

030/001662

Annex to Certificate

Type Ref.	No. of poles	Rated current	Rated voltage	Rated residual operating current	Rated short-circuit capacity	Rated residual making and breaking capacity	Tripping	Type	Energy limiting class	Additional information
GW95107	1P+N	16A	230 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95108	1P+N	20A	230 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95109	1P+N	25A	230 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95110	1P+N	32A	230 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95111	1P+N	13A	230 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95115	1P+N	6A	230 V-	300 mA	6000 A	6000 A	B	A	1	(1)
GW95116	1P+N	10A	230 V-	300 mA	6000 A	6000 A	B	A	1	(1)
GW95117	1P+N	16A	230 V-	300 mA	6000 A	6000 A	B	A	1	(1)
GW95118	1P+N	20A	230 V-	300 mA	6000 A	6000 A	B	A	1	(1)
GW95119	1P+N	25A	230 V-	300 mA	6000 A	6000 A	B	A	1	(1)
GW95120	1P+N	32A	230 V-	300 mA	6000 A	6000 A	B	A	1	(1)
GW95125	2P	6A	230 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95126	2P	10A	230 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95127	2P	16A	230 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95128	2P	20A	230 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95129	2P	25A	230 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95130	2P	32A	230 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95131	2P	13A	230 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95135	2P	6A	230 V-	300 mA	6000 A	6000 A	B	A	1	(1)
GW95136	2P	10A	230 V-	300 mA	6000 A	6000 A	B	A	1	(1)
GW95137	2P	16A	230 V-	300 mA	6000 A	6000 A	B	A	1	(1)
GW95138	2P	20A	230 V-	300 mA	6000 A	6000 A	B	A	1	(1)
GW95139	2P	25A	230 V-	300 mA	6000 A	6000 A	B	A	1	(1)
GW95140	2P	32A	230 V-	300 mA	6000 A	6000 A	B	A	1	(1)
GW95145	3P	6A	400 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95146	3P	10A	400 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95147	3P	16A	400 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95148	3P	20A	400 V-	30 mA	6000 A	6000 A	B	A	1	(1)

First issued on 2002-05-17
Modified on 2017-12-14
Validity date 2020-07-14

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate Low Voltage Material

030/001662

Annex to Certificate

Type Ref.	No. of poles	Rated current	Rated voltage	Rated residual operating current	Rated short-circuit capacity	Rated residual making and breaking capacity	Tripping	Type	Energy limiting class	Additional information
GW95149	3P	25A	400 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95150	3P	32A	400 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95151	3P	13A	400 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95155	3P	6A	400 V-	300 mA	6000 A	6000 A	B	A	1	(1)
GW95156	3P	10A	400 V-	300 mA	6000 A	6000 A	B	A	1	(1)
GW95157	3P	16A	400 V-	300 mA	6000 A	6000 A	B	A	1	(1)
GW95158	3P	20A	400 V-	300 mA	6000 A	6000 A	B	A	1	(1)
GW95159	3P	25A	400 V-	300 mA	6000 A	6000 A	B	A	1	(1)
GW95160	3P	32A	400 V-	300 mA	6000 A	6000 A	B	A	1	(1)
GW95165	4P	6A	400 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95166	4P	10A	400 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95167	4P	16A	400 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95168	4P	20A	400 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95169	4P	25A	400 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95170	4P	32A	400 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95171	4P	13A	400 V-	30 mA	6000 A	6000 A	B	A	1	(1)
GW95175	4P	6A	400 V-	300 mA	6000 A	6000 A	B	A	1	(1)
GW95176	4P	10A	400 V-	300 mA	6000 A	6000 A	B	A	1	(1)
GW95177	4P	16A	400 V-	300 mA	6000 A	6000 A	B	A	1	(1)
GW95178	4P	20A	400 V-	300 mA	6000 A	6000 A	B	A	1	(1)
GW95179	4P	25A	400 V-	300 mA	6000 A	6000 A	B	A	1	(1)
GW95180	4P	32A	400 V-	300 mA	6000 A	6000 A	B	A	1	(1)
GW95805	2P	6 A	230 V-	30 mA	6000 A	4500 A	C	A	3	(1)
GW95806	2P	10 A	230 V-	30 mA	6000 A	4500 A	C	A	3	(1)
GW95807	2P	16 A	230 V-	30 mA	6000 A	4500 A	C	A	3	(1)
GW95808	2P	20 A	230 V-	30 mA	6000 A	4500 A	C	A	3	(1)
GW95809	2P	25 A	230 V-	30 mA	6000 A	4500 A	C	A	3	(1)
GW95810	2P	32 A	230 V-	30 mA	6000 A	4500 A	C	A	3	(1)

First issued on 2002-05-17
Modified on 2017-12-14
Validity date 2020-07-14

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate Low Voltage Material

030/001662

Annex to Certificate

Type Ref.	No. of poles	Rated current	Rated voltage	Rated residual operating current	Rated short-circuit capacity	Rated residual making and breaking capacity	Tripping	Type	Energy limiting class	Additional information
GW95811	2P	13 A	230 V-	30 mA	6000 A	4500 A	C	A	3	(1)
GW95815	4P	6 A	400 V-	30 mA	6000 A	4500 A	C	A	1	(1)
GW95816	4P	10 A	400 V-	30 mA	6000 A	4500 A	C	A	1	(1)
GW95817	4P	16 A	400 V-	30 mA	6000 A	4500 A	C	A	1	(1)
GW95818	4P	20 A	400 V-	30 mA	6000 A	4500 A	C	A	1	(1)
GW95819	4P	25 A	400 V-	30 mA	6000 A	4500 A	C	A	1	(1)
GW95820	4P	32 A	400 V-	30 mA	6000 A	4500 A	C	A	1	(1)
GW95821	4P	13 A	400 V-	30 mA	6000 A	4500 A	C	A	1	(1)
GW95847	2P	16 A	230 V-	300 mA	6000 A	4500 A	C	A	3	(1)
GW95848	2P	20 A	230 V-	300 mA	6000 A	4500 A	C	A	3	(1)
GW95849	2P	25 A	230 V-	300 mA	6000 A	4500 A	C	A	3	(1)
GW95850	2P	32 A	230 V-	300 mA	6000 A	4500 A	C	A	3	(1)
GW95857	4P	16 A	400 V-	300 mA	6000 A	4500 A	C	A	1	(1)
GW95858	4P	20 A	400 V-	300 mA	6000 A	4500 A	C	A	1	(1)
GW95859	4P	25 A	400 V-	300 mA	6000 A	4500 A	C	A	1	(1)
GW95860	4P	32 A	400 V-	300 mA	6000 A	4500 A	C	A	1	(1)

(1) These circuit-breakers are for use at ambient air temperature from -25°C to 40°C. Should be back up protected by 63 A fuse.

Original Electronic Certificate

First issued on 2002-05-17
Modified on 2017-12-14
Validity date 2020-07-14

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com