



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **21233-002-01**

Valid from: 2020 09 07
until: 2022 09 07

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **GEWISS SPA**
Via A. Volta 1
24069 Cenate Sotto (Bergamo)
Italy

Product: **Residual current operated circuit-breakers (RCCBs) with automatic test device**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **3387-1766/18**

Österreichischer Verband für Elektrotechnik
Head of Testing and Certification

Digitally signed by W. Martin
Email=w.martin@ove.at

Dipl.-Ing. W. Martin

Wien, 2020 07 08



OVE Testing and Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.



Manufacturer:

GEWISS SPA
Via A. Volta 1
24069 Cenate Sotto (Bergamo)
Italy

Factory location(s):

GEWISS Portugal - Industrial de Material Eléctrico Unipessoal, Limitada
Zona Industrial 2° fase
4560-043 Bustelo, Penafiel
Portugal

Tested and certified according to:

OVE EN 61008-1:2018-04-01
ÖVE EN 61008-2-1+A11:1998-06
OVE E 8601:2018-03-01

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**.

Product: Residual current operated circuit-breakers (RCCBs) with automatic test device

Type designation:

Rating:

Trademark:

GW90931G

Rated voltage: AC 230 V
Rated current: 25 A
1P+N
30 mA, Typ A, Typ G
Im = 630 A; Inc = 10000 A
-25°C bis +40°C
with AUTOTEST module

GEWISS

GW90932G

Rated voltage: AC 230 V
Rated current: 40 A
1P+N
30 mA, Typ A, Typ G
Im = 630 A; Inc = 10000 A
-25°C bis +40°C
with AUTOTEST module

GEWISS

OVE Testing and Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.

GW90933G

GEWISS

Rated voltage: AC 230 V

Rated current: 63 A

1P+N

30 mA, Typ A, Typ G

Im = 630 A; Inc = 10000 A

-25°C bis +40°C

with AUTOTEST module

GW90941G

GEWISS

Rated voltage: AC 400 V

Rated current: 25 A

3P+N

30 mA, Typ A, Typ G

Im = 630 A; Inc = 10000 A

-25°C bis +40°C

with AUTOTEST module

GW90942G

GEWISS

Rated voltage: AC 400 V

Rated current: 40 A

3P+N

30 mA, Typ A, Typ G

Im = 630 A; Inc = 10000 A

-25°C bis +40°C

with AUTOTEST module

GW90943G

GEWISS

Rated voltage: AC 400 V

Rated current: 63 A

3P+N

30 mA, Typ A, Typ G

Im = 630 A; Inc = 10000 A

-25°C bis +40°C

with AUTOTEST module

OVE Testing and Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.