

Attuatore combinato 4 ch 10A + 4 IN/OUT universali

KNX - da guida DIN

KNX combined 4-channel 10A actuator + 4 universal





I/O - DIN rail

Actionneur combiné 4 canaux 10A + 4 E/S universelles

KNX - sur rail DIN



GW 90 854 - CVD type GW 90 855 - CCD type



AVVERTENZE PER L'INSTALLAZIONE KNX

1. La lunghezza della linea bus tra l'attuatore dimmer e l'alimentatore non deve superare i 1350 metri.
2. La lunghezza della linea bus tra l'attuatore dimmer e il più lontano dispositivo KNX non deve superare i 700 metri.
3. Per evitare segnali e sovrappressioni non voluti, non dar vita a circuiti ad anello.
4. Mantenere una distanza di almeno 4 mm tra i cavi singolarmente isolati della linea bus e quelli della linea elettrica (figura C).
5. Non danneggiare il conduttore di continuità elettrica della schermatura (figura D).

ATTENZIONE: i cavi di segnale del bus non utilizzati e il conduttore di continuità elettrica non devono mai toccare elementi sotto tensione o il conduttore di terra!

MONTAGGIO SU GUIDA DIN

Montare il dimmer su guida DIN da 35 mm nel seguente modo (figura E):

1. Inserire l'aggancio superiore del dispositivo nella guida DIN.
2. Ruotare il dispositivo e bloccarlo sulla guida DIN agendo sulla linguetta di fissaggio.

CONNESSIONI ELETTRICHE

ATTENZIONE: disinserire la tensione di rete prima di connettere il dispositivo alla rete elettrica!

La figura B mostra lo schema delle connessioni elettriche.

1. Collegare il filo rosso del cavo bus al morsetto rosso (+) del terminale e il filo nero al morsetto nero (-). Al terminale bus si possono collegare fino a 4 linee bus (filo dello stesso colore nello stesso morsetto) (figura F).
2. Isolare lo schermo, il conduttore di continuità elettrica e i rimanenti fili bianco e giallo del cavo bus (nel caso in cui si utilizzi un cavo bus a 4 conduttori), che non sono necessari (figura D).
3. Inserire il morsetto bus negli appositi piedini del dispositivo. Il corretto senso di inserzione è determinato dalle guide di fissaggio. Isolare il morsetto bus usando l'apposito coperchietto, che deve essere fissato al dispositivo con la sua vite. Il coperchietto garantisce la separazione minima di 4 mm tra i cavi di potenza e i cavi bus. (figura G).
4. Collegare il carico agli appositi morsetti a vite posti sotto l'attuatore, controllando di non superare i limiti di corrente specificati nei Dati tecnici.

USO DEI PULSANTI DI COMANDO LOCALE

I pulsanti frontalib di test (figura A) consentono di effettuare la commutazione ciclica ON/OFF dei canali o la regolazione di luminosità da 0% a 100% e viceversa ad ogni pressione (impostazione di default).

I comandi locali sono eseguiti anche nel caso in cui sia attivo un comando prioritario.

COMPORTEAMENTO ALLA CADUTA E AL RIPRISTINO DELL'ALIMENTAZIONE BUS

Se la tensione del bus scende sotto i 18V dc per più di 1,5 ms il dimmer porta tutti i canali di uscita in OFF (valore luminosità 0%). È possibile configurare il comportamento dei canali di uscita alla caduta tensione bus, secondo la procedura seguente.

Ingresso modalità configurazione:

- premere il tasto di programmazione: il LED rosso di programmazione si accende;
- premere contemporaneamente per almeno 3 secondi i pulsanti di comando locali 1 e 4;
- attendere che venga emesso un lampaggio verde dei 4 LED di stato.

Una volta entrati nella fase di configurazione, tutti i canali vengono disattivati (valore luminosità 0%) ed i LED mostrano l'attuale stato di configurazione di ogni singolo canale, come da tabella.

Led di stato 1..4	Stato canale alla caduta tensione
Spento	Luminosità 0%
Verde fisso	Luminosità 100%
Verde lampeggiante (1 Hz)	Come prima della caduta di tensione

È possibile modificare l'impostazione di ogni singolo canale agendo sul tasto relativo, in modo da scorrere in sequenza le tre configurazioni disponibili. Nel caso in cui il carico selezionato fosse RGBW, l'impostazione riguarda tutti i colori per i cui LED dovranno essere allineati e la pressione di qualsiasi pulsante locale associato ai canali modificherà l'impostazione di tutti i colori.

Nel caso in cui il carico selezionato fosse RGB + monocolor, i LED 1, 2 e 3 dovranno essere allineati segnalando l'impostazione del canale RGB e la pressione di qualsiasi pulsante locale associato ai canali 1, 2 e 3 modificherà l'impostazione dei tre colori; è possibile modificare l'impostazione del canale 4 agendo sul tasto corrispondente.

Uscita modalità configurazione:

- per salvare le nuove impostazioni: premere il pulsante di programmazione;
- per uscire senza salvare le impostazioni: lasciar trascorrere 10 secondi (dall'ultima pressione di un pulsante).

La fine modalità di configurazione viene segnalata attraverso lo spegnimento del LED di programmazione.

All'uscita dalla fase di configurazione viene ripristinato lo stato dei canali precedente all'ingresso nella procedura stessa.

In questa fase di configurazione i messaggi provenienti dal bus vengono ignorati (verranno gestiti dall'uscita della configurazione).

COMPORTEAMENTO ALLA CADUTA E AL RIPRISTINO DELL'ALIMENTAZIONE AUSILIARIA LED

Alla caduta dell'alimentazione ausiliaria il dimmer porta tutti i canali di uscita in OFF (valore luminosità 0%). Durante l'assenza dell'alimentazione ausiliaria il dimmer continua a processare i comandi come se la rete fosse presente, rispettando le priorità relative; al ripristino dell'alimentazione ausiliaria il dimmer esegue l'ultimo comando ricevuto.

Il comportamento al ripristino dell'alimentazione ausiliaria non viene eseguito se l'alimentazione viene a mancare mentre è in corso l'allarme surriscaldamento.

SELEZIONE CARICO DA CONTROLLARE E CORRENTE DI PILOTAGGIO

È possibile impostare la corrente di pilotaggio e il carico da controllare, secondo la procedura seguente.

Ingresso modalità configurazione:

- premere il tasto di programmazione: il LED rosso di programmazione si accende;
- premere contemporaneamente per almeno 3 secondi i pulsanti di comando locali 2 e 3;
- attendere che venga emesso un lampaggio verde dei 4 LED di stato.

Una volta entrati nella fase di configurazione, tutti i canali vengono disattivati (valore luminosità 0%) mentre i LED relativi ai canali 1, 2 e 3 mostrano l'attuale stato di configurazione della corrente di pilotaggio, come da tabella.

Corrente di pilotaggio	LED 1	LED 2	LED 3
350 mA	rosso fisso	spento	Spento
500 mA	spento	rosso fisso	Spento
700 mA	spento	Spento	rosso fisso

E' possibile modificare l'impostazione agendo sul tasto relativo.

Carico da controllare	LED 4
RGBW	giallo fisso
monocolor	giallo lampeggiante (1 Hz)
RGB + monocolor	verde lampeggiante (1 Hz)

E' possibile modificare l'impostazione ag

ENGLISH

GENERAL WARNINGS

WARNING: The safety of this appliance is only guaranteed if all the instructions given here are followed scrupulously. These should be read thoroughly and kept in a safe place.

Chorus products can be installed in environments which are dust-free and where no special protection against the penetration of water is required.

They shall be installed in compliance with the requirements for household devices set out by the national standards and rules applicable to low-voltage electrical installations which

are in force in the country where the products are installed, or, when there are none, following the international standard for low-voltage electrical installations IEC 60364, or the European harmonization document HD 60364. Gewiss sales organization is ready to provide full explanations and technical data on request.

Gewiss SpA reserves the right to make changes to the product described in this manual at any time and without giving any notice.

PACK CONTENTS

- 1 EASY dimmer actuator for LED - DIN rail mounting
- 1 Bus terminal
- 1 Cover with screw
- 1 User and Installation Manual

BRIEFLY

The EASY dimmer actuators for LEDs powered with continuous voltage (Vdc) - DIN rail mounted, are devices for adjusting the brightness for max. 4 single colour LEDs or LED RGB[W] strips and spotlights. They are available in two versions:
 - CVD (constant voltage control) for controlling single colour or RGB[W] strips;
 - CCD (constant current control) for controlling power LEDs (single colour or RGB[W]).
 The dimmer actuators are powered by the BUS line and are equipped with 4 two-toned front LEDs that indicate the status of the outputs, 4 front control button keys for testing the outputs, 1 red LED for signalling any faults, 1 relay contact for controlling the network voltage of the LED auxiliary power supply, 4 independent output channels. The dimmer actuator is assembled on a DIN rail, inside electric boards or junction boxes.

FUNCTIONS

The dimmer actuator can be configured with the Easy controller to perform one of the following functions:

ON/OFF SWITCHING (*)

The dimmer actuator activates the corresponding channel to the last stored brightness value or deactivates it (0%) when it receives the ON/OFF commands sent, for example, from a contacts interface or a push-button panel configured in Cyclical ON/OFF switching mode or Fronts management mode.

RGB[W] RELATIVE BRIGHTNESS CONTROL (*)

This is used to increase or decrease the brightness level of the channel based on the commands received from other KNX devices. When a stop command is received, the control is stopped and the brightness level that has been reached is maintained. If the load type is RGBW (or RGB + 1 single colour), it is possible to regulate colour brightness.

RGB[W] ABSOLUTE BRIGHTNESS CONTROL (*)

This is used to set the absolute percentage brightness value defined by the command that was received. The brightness value is reached over a ramp. If the load type is RGBW (or RGB + 1 single colour), it is possible to regulate colour brightness.

SCENES (*)

The dimmer actuator can memorise and manage up to 8 scenes. The light intensity values can be memorised and called up via Easy devices or conventional push-buttons connected to the BUS via a contacts interface. You can create a maximum of 8 scenes, with varying light intensity values. When it receives the command, the dimmer brings the load to the value previously set.

COLOUR SEQUENCES AND LIGHT SEQUENCES

If the load type is RGBW (or RGB + 1 single colour), it is possible to manage 5 pre-configured colour sequences (single colour strobe, single colour blinking, colour brightness scale, rainbow, rainbow strobe). If the load type is single colour, it is possible to manage 2 different preconfigured light sequences for each channel (strobe and blinking).

PRIORITY COMMAND (FORCING) (*)

The dimmer actuator activates the corresponding channel to the last stored brightness value or deactivates it (0%) on the basis of the command (ON or OFF) transmitted by the device that sends the priority command. Until it receives a command to annul the forcing, the dimmer ignores all the other commands received (including commands from the front push-button). If no other commands are received, at the end of the forcing the actuator will return to the status it had before the forcing activation. Otherwise, it will assume the status of the last command that was received.

TIMED SWITCHING (STAIR RAISER LIGHT) (*)

The dimmer actuator activates the corresponding channel to the last stored brightness value for the time specified by the Activation time parameter and then deactivates it (brightness value 0%) when this period has elapsed. For instance, this is the setting for the stair raiser light. If the dimmer actuator receives a new ON command with timing during the activation period, the time count starts again from the beginning. If an OFF command is sent before the time has elapsed, the light will be switched off. With the Pre-warning time parameter, you can enable the switch-off pre-warning: in this case, the device decreases the light intensity value for the set time leading up to switch-off. You can therefore send a new timed command before the light switches off completely.

(*) for each single channel and the 4 channels simultaneously

FRONT LED INDICATORS

	Channel status indicator LED	Fault signalling LED
No fault, load piloted	Fixed GREEN	Off
No fault, load off	Off	Off
Overheating	Off	Fixed RED
Returns below the temperature threshold after overheating	Flashing GREEN	Fixed RED
Reset test after overheating	Flashing RED	Fixed RED
Auxiliary voltage polarity inversion	Off	Flashing RED
Absence of auxiliary voltage	Flashing YELLOW	Fixed RED

INSTALLATION

ATTENTION: the device must only be installed by qualified personnel, observing the current regulations and guidelines for KNX installations.

RECOMMENDATIONS FOR INSTALLING THE KNX

- 1. The length of the BUS line between the dimmer actuator and the power supply unit must not exceed 350 metres.
- 2. The length of the BUS line between the dimmer actuator and the furthest KNX device must not exceed 700 metres.
- 3. To avoid unwanted signals and overvoltages, do not use ring circuits.
- 4. Keep a distance of at least 4mm between the individually insulated cables of the BUS line and those of the electricity line (figure C)
- 5. Do not damage the electrical continuity conductor of the shielding (figure D).

ATTENTION: the unused BUS signal cables, and the electrical continuity conductor, must never touch any live elements or the earthing conductor!

ASSEMBLY ON THE DIN RAIL

Assemble the dimmer on a 35mm DIN rail in the following way (figure E):

1. Insert the upper device coupling in the DIN rail.
2. Rotate the device, then lock it in place on the DIN rail by means of the fixing tab.

ELECTRIC CONNECTIONS

ATTENTION: disconnect the mains voltage before connecting the device to the electricity supply!

Figure B shows a diagram of the electrical connections.

1. Connect the red wire of the BUS cable to the red clamp (+) of the terminal, and the black wire to the black clamp (-). Up to 4 A BUS lines can be connected to the BUS terminal (same coloured wires on the same terminal) (figure F).
2. Insulate the shield, the electrical continuity conductor, and the other white and yellow wires of the BUS cable (if a 4-conductor BUS cable is being used), that are not necessary (figure D).
3. Insert the BUS clamp in the pins of the device. The correct connection direction is determined by the fixing rails. Insulate the BUS terminal with the special cover, that must be screwed onto the device. The cover guarantees the minimum separation distance of 4mm between the power cables and the BUS cables (figure G).
4. Connect the load to the relevant screw terminals underneath the actuator, making sure the current limits specified in the Technical Data are not exceeded.

USE OF THE PUSH-BUTTONS FOR LOCAL COMMAND

The front test push-buttons (figure A) are used to perform the cyclical ON/OFF switching of the channels or brightness control from 0% to 100% and vice versa each time they are pressed (default setting).

The local commands are executed also if a priority command is active.

BEHAVIOUR UPON THE FAILURE AND RESETTING OF THE BUS POWER SUPPLY

If the BUS voltage falls below 18 V DC for more than 1.5 ms, the dimmer switches all the output channels to OFF (brightness value 0%). The behaviour of the output channels can be configured when the BUS voltage fails, by observing the following procedure.

Accessing configuration mode:

- press the button key for programming: red LED for programming turns on;
- press local command push-buttons 1 and 4 simultaneously for at least 3 seconds;
- wait until the 4 green status LEDs start to blink.

Once the configuration phase has started, all channels are deactivated (brightness value 0%) and the LEDs will show the current configuration status for each channel (as per the table).

Status LED 1..4	Channel status when voltage fails
Off	Brightness 0%
Fixed GREEN	Brightness 100%
Blinking green (1 Hz)	As before voltage drop

You can modify the setting of the each channel using the relative button key, in order to scroll through the three available configurations in sequence. If the selected load is RGBW, the setting concerns all the colours for which the LEDs must be aligned and pressing any local push-button associated with the channels will change the setting for all colours.

If the selected load is RGB + single colour, LEDs 1, 2 and 3 must be aligned signalling the setting of the RGB channel and pressing any local push-button associated with channels 1, 2 and 3 will change the setting of the three colours; the setting for channel 4 can be changed using the corresponding button key.

Quitting configuration mode:

- to save the new settings: press the programming push-button;
- to quit without saving the settings: wait 10 seconds (from the last pressing of a push-button).

The end of configuration mode is signalled by the switching off of the programming LED. When you have quit the configuration phase, the channels will be restored to the status they held prior to that phase.

During this configuration phase, the messages from the BUS are ignored (they will be managed after you have quit the configuration phase).

BEHAVIOUR UPON FAILURE AND RESETTING OF THE LED AUXILIARY POWER SUPPLY

The dimmer actuator activates the corresponding channel to the last stored brightness value for the time specified by the Activation time parameter and then deactivates it (brightness value 0%) when this period has elapsed. For instance, this is the setting for the stair raiser light. If the dimmer actuator receives a new ON command with timing during the activation period, the time count starts again from the beginning. If an OFF command is sent before the time has elapsed, the light will be switched off. With the Pre-warning time parameter, you can enable the switch-off pre-warning: in this case, the device decreases the light intensity value for the set time leading up to switch-off.

The behaviour when the auxiliary power supply is restored is not executed if the power supply failed while the overheating alarm was in progress.

SELECTION OF THE LOAD TO BE CONTROLLED AND THE PILOT CURRENT

The pilot current and the load to be controlled can be set according to the following procedure.

Accessing configuration mode:

- press the button key for programming: red LED for programming turns on;
- press local command push-buttons 2 and 3 simultaneously for at least 3 seconds;
- wait for the 4 green status LEDs start to blink.

Once the configuration phase has started, all channels are deactivated (brightness value 0%) and the LEDs relative to channels 1, 2 and 3 will show the current configuration status of the pilot current (as per the table).

Pilot current	LEDs 1	LEDs 2	LEDs 3
350 mA	fixed red	off	off
500 mA	off	fixed red	off
700 mA	off	off	fixed red

Certifications

KNX



It Seguire le istruzioni e conservare per la consegna all'utente finale. Evitare qualsiasi uso improprio, manomissioni e modifiche. Rispettare le vigenti norme sugli impianti - EN Follow the instructions and keep them safe for delivery to the end user. Avoid any misuse, tampering and modifications. Comply with the current regulations regarding the systems - FR Observer les consignes et les directives relatives aux installations KNX.

The setting can be changed using the relative button key. The LED relative to channel 4 displays the current configuration status of the load to be controlled, as per the table:

Load to be controlled	LEDs 4
RGBW	fixed yellow
single colour	blinking yellow (1 Hz)
RGB + single colour	blinking green (1 Hz)

You can modify the setting using the relative button key, in order to scroll the two available configurations in sequence.

Quitting configuration mode:

- to save the new settings: press the programming push-button;
- to quit without saving the settings: wait 10 seconds (from the last pressing of a push-button).

The end of configuration mode is signalled by the switching off of the programming LED.

When you have quit the configuration phase, the channels will be restored to the status they held prior to that phase.

During this configuration phase, the messages from the BUS are ignored (they will be managed after you have quit the configuration phase).

FRANÇAIS

CONSIGNES GÉNÉRALES

ATTENTION: La sécurité de l'appareil n'est garantie que si l'on respecte les instructions mentionnées ci-joint. Il est donc nécessaire de les lire avec attention et de bien les conserver.

Tous produits de la gamme Chorus doivent être installés en conformité avec les normes HD 384 / IEC364 sur les appareils à usage domestique et similaire, dans des milieux non poussiéreux et où il n'est pas nécessaire d'avoir une protection spéciale contre la pénétration d'eau. L'organisation de vente GEWISS est à votre disposition pour toute élucidation ou information technique.

5. Ne pas déteriorer le conducteur de continuité électrique du blindage (figure D).

ATTENTION: les câbles de signal du bus non utilisés et le conducteur de continuité électrique ne doivent jamais toucher des éléments sous tension ou le conducteur de terre !

MONTAGE SUR RAIL DIN

Monter le variateur sur un rail DIN de 35 mm de la manière suivante (figure E):

1. Insérer l'accrochage supérieur du dispositif sur le rail DIN.
2. Tourner le dispositif et le bloquer sur le rail DIN en agissant sur la languette de fixation.

CONNEXIONS ÉLECTRIQUES

ATTENTION: couper la tension de réseau avant de connecter le dispositif au réseau électrique !

La figure B rapporte le schéma des connexions électriques.

1. Connecter le fil rouge du câble bus à la borne rouge (+) du terminal et le fil noir à la borne noire (-). On pourra raccorder, au terminal bus, jusqu'à 4 lignes bus (fil de même couleur sur la même borne) (figure F).
2. Isoler le blindage, le conducteur de continuité électrique et les fils blanc et jaune restants du câble bus (si l'on utilise un câble bus à 4 conducteurs) qui ne s'avèrent pas nécessaires (figure D).

Les actionneurs variateurs d'intensité lumineuse sont alimentés par la ligne bus et sont dotés de 4 voyants bicolores en façade indiquant l'état des sorties, de 4 touches de commande en façade de test des sorties, d'un voyant rouge de signalisation des défauts, d'un contact du relais pour le pilotage de la tension du réseau de l'alimentation auxiliaire des sorties et d'un voyant de surchauffe en vert en fonction de la température de service.

Les actionneurs variateurs d'intensité lumineuse sont alimentés par la ligne bus et sont dotés de 4 voyants bicol