




SCHEMA CIRCUITALE INDICATIVO PER LA COMMUTAZIONE AUTOMATICA DI DUE INTERRUTTORI MTX/E 320 - MTX/E 630 - MTX/E 1000

INDICATIVE CIRCUIT DIAGRAM FOR THE AUTOMATIC CHANGING OVER OF TWO MTX/E 320 - MTX/E 630 - MTX/E 1000

MTX/E 320 - MTX/E 630 - MTX/E 1000


74279845

(1SDM000035R0.001-L2552)

GEWISS

1/6

INTERRUTTORI CON RELE' DI MASSIMA CORRENTE / CIRCUIT BREAKERS WITH OVERCURRENT RELAY



NEL CASO DI ALIMENTAZIONE DI EMERGENZA ATTRAVERSO GENERATORE DIESEL
IN CASE OF EMERGENCY SUPPLY BY DIESEL GENERATOR

AVVAMENTO GENERATORE DIESEL
DIESEL GENERATOR STARTING

ARRESTO GENERATORE DIESEL
DIESEL GENERATOR STOPPING

MTX/E 320 - MTX/E 630 - MTX/E 1000


74279845

(1SDM000035R0.001-L2552)

GEWISS

2/6

INTERRUTTORI SENZA RELE' DI MASSIMA CORRENTE / CIRCUIT BREAKERS WITHOUT OVERCURRENT RELAY



MTX/E 320 - MTX/E 630 - MTX/E 1000

74279845

(15DM000035R0.001-L2552)

GEWISS

3/6

SEGNI GRAFICI PER SCHEMI ELETTRICI (NORME IEC 617 E CEI 3-14...3-26) GRAPHICAL SYMBOLS FOR ELECTRICAL DIAGRAMS (617 IEC STANDARDS)

SEGNO SYMBOL	IEC REF. NUMBER	LEGENDA CAPTION					
			•	03-02-01	-CONNESSIONE DI CONDUTTORI -CONNECTION OF CONDUCTORS		(07-11-06)
	02-08-01	-EFFETTO TERMICO -THERMAL EFFECT	•	03-02-02	-TERMINALE O MORSETTO -TERMINAL		(07-13-10)
	02-08-02	-EFFETTO ELETTROMAGNETICO -ELECTROMAGNETIC EFFECT		03-03-05	-PRESA E SPINA (FEMMINA E MASCHIO) -PLUG AND SOCKET (MALE AND FEMALE)		07-15-01
---	02-12-01	-COLLEGAMENTO MECCANICO, PNEUMATICO O IDRAULICO -MECHANICAL, PNEUMATIC OR HYDRAULIC CONNECTION (LINK)		06-04-01	-MOTORE (SEGNO GENERALE) -MOTOR (GENERAL SYMBOL)		07-15-07
	02-12-05	-MOVIMENTO RITARDATO (NEL SENSO DELLO SPOSTAMENTO DELL'ARCO VERSO IL PROPRIO CENTRO) -DELAYED ACTION (IN THE DIRECTION OF MOVEMENT FROM THE ARC TOWARDS ITS CENTRE)		06-09-11	-TRASFORMATORE DI CORRENTE -CURRENT TRANSFORMER		07-15-08
---∇---	02-12-11	-INTERBLOCCO MECCANICO TRA DUE APPARECCHI -MECHANICAL INTERLOCK BETWEEN TWO DEVICES		07-02-01	-CONTATTO DI CHIUSURA -MAKE CONTACT		07-21-08
---	02-13-01	-COMANDO MECCANICO MANUALE (CASO GENERALE) -MANUALLY OPERATED CONTROL (GENERAL CASE)		07-02-03	-CONTATTO DI APERTURA -BREAK CONTACT		
	02-13-13	-COMANDO A CHIAVE -OPERATED BY KEY		07-02-04	-CONTATTO DI SCAMBIO CON INTERRUZIONE MOMENTANEA -CHANGE-OVER BREAK BEFORE MAKE CONTACT		
	02-13-16	-COMANDO A CAMMA -OPERATED BY CAM		07-08-01	-CONTATTO DI POSIZIONE DI CHIUSURA (FINE CORSA) -POSITION SWITCH (LIMIT SWITCH), MAKE CONTACT		
	02-13-26	-COMANDO A MOTORE ELETTRICO -OPERATED BY ELECTRIC MOTOR		07-08-02	-CONTATTO DI POSIZIONE DI APERTURA (FINE CORSA) -POSITION SWITCH (LIMIT SWITCH), BREAK CONTACT		

MTX/E 320 - MTX/E 630 - MTX/E 1000

74279845

(15DM000035R0.001-L2552)

GEWISS

4/6

STATO DI FUNZIONAMENTO RAPPRESENTATO Lo schema è rappresentato nelle seguenti condizioni: – interruttori aperti e inseriti # – circuiti in assenza di tensione – sganciatori non intervenuti * – comando a motore con molle cariche. # The present diagram represents circuit breakers in execution removable but it is valid also for circuit breakers in fixed version. * The present diagram represents circuit breakers with overcurrent relay but it is valid also for circuit breakers without overcurrent relay (switch-disconnectors). For c. breakers with overcurrent relay see the circuits indicated on sheet 2, for c. breakers without overcurrent relay see the circuits indicated on sheet 3. LEGENDA A = Gruppo di commutazione automatica (per la messa in servizio vedi nota D) A17 = Unità per la ritenuta elettrica del motore M F1–F2 = Sezionatori con fusibile di protezione incorporato K27/Q1 = Relè di misura della tensione della linea di alimentazione di emergenza K27/Q1D = Relè ausiliario con ritardo alla diseccitazione (vedi nota F) K27/Q2 = Relè di misura della tensione della linea di alimentazione normale K27/Q2D = Relè ausiliario con ritardo alla diseccitazione (vedi nota F) K27/Q2E = Relè ausiliario con ritardo all'eccitazione (vedi nota F) K51/Q1 = Relè di massima corrente della linea di alimentazione di emergenza K51/Q2 = Relè di massima corrente della linea di alimentazione normale K83 = Relè per la commutazione automatica M = Motore per l'apertura dell'interruttore e la carica delle molle di chiusura dell'interruttore Q1 = Interruttore della linea di alimentazione di emergenza Q2 = Interruttore della linea di alimentazione normale Q61 = Interruttore termomagnetico per il sezionamento e la protezione dei circuiti ausiliari S1,S2 = Contatti comandati dalla camma del comando a motore S3 = Contatto comandato dal blocco a chiave del comando a motore S43 = Commutatore a due posizioni per l'abilitazione della commutazione automatica SY/Q1 = Contatto per la segnalazione elettrica di interruttore Q1 aperto per intervento degli sganciatori (vedi nota B) SY/Q2 = Contatto per la segnalazione elettrica di interruttore Q2 aperto per intervento degli sganciatori (vedi nota B) TI/... = Trasformatori di corrente per l'alimentazione del relè di massima corrente XA7–XAB = Connettori per i circuiti ausiliari dell'interruttore (vedi nota B) YC = Sganciatore di chiusura del comando a motore NOTE A) For the auxiliary circuits of the circuit breakers see the diagram 1SDM000030R0.001. The applications indicated by the following figures are mandatory: 11–23 (or 22 if overcurrent relay is supplied). B) In case of tripping of the overcurrent relay of one of c. breakers, for resetting set the S43 selector-switch in MAN. position, reset the tripped c. breakers manually and then set the S43 selector-switch in AUT. position. C) Do not connect or isolate the c. breakers in withdrawable or plug-in version when the S43 selector-switch is in AUT. position. D) When putting the automatic changing-over in service, carry out the following operations: 1) set the S43 selector-switch in MAN. position, Q61 c. breaker must be open 2) close the Q61 c. breaker 3) wait for a period of time higher than the delay set on the K27/Q2 relay 4) set the S43 selector-switch in AUT. position E) The auxiliary voltage supplies shall be of safety type (not on network). F) The programming of delay times between receiving signals of voltage absence or presence and sending off the opening and closing controls to the c. breakers, must be carried out using the timers of K27/Q1D, K27/Q2D and K27/Q2E relays, considering that the c. breaker opening occurs in 1.5s while the closing occurs in 100 ms. In particular the delay of the K27/Q2D relay determines the delay time of the beginning of the changing-over sequence between the normal supply line and the emergency one, as regards the moment in which there is no normal supply voltage. This type of delay is useful for avoiding untimely changing-overs, which are caused by small voltage gaps. The delay of the K27/Q2E relay, on the other hand, determines the delay time of the beginning of the changing-over sequence between the emergency supply line and the normal one, as regards the moment in which the normal supply voltage returns. It is advisable to set this delay to high values, in order to avoid an unwanted changing-over when the normal supply line is unstable. The delay of the K27/Q1D relay is useful for avoiding untimely opening of the emergency line c. breaker, which are caused by small voltage gaps. G) The diagram indicates c. breakers with auxiliary circuits connected to XA7 and XAB connectors. For c. breakers without XA7 and XAB connectors see the circuits corresponding with 1SDM000030R0.001 diagram.			
MTX/E 320 - MTX/E 630 - MTX/E 1000		74279845 (1SDM00003SR0.001-L2S52)	GEWISS 5/6

REPRESENTED OPERATIONAL STATE The diagram indicates the following conditions: – c. breakers off and connected # – circuits de-energized – overcurrent relays not tripped * – motor operator with charged springs. # The diagram indicates c. breakers in plug-in version but it may be applied also to c. breakers in fixed version. * The diagram indicates c. breakers equipped with overcurrent relay but it may be applied also to c. breakers without overcurrent relay (switch-disconnectors). For c. breakers with overcurrent relay see the circuits indicated on sheet 2, for c. breakers without overcurrent relay see the circuits indicated on sheet 3. CAPTION A = Automatic changing-over switchgear (for putting the system in service see note D) A17 = Unit for M motor electrical latching F1–F2 = Protective fuse-disconnectors K27/Q1 = Voltage measuring relay for emergency supply line K27/Q1D = Auxiliary relay delayed on de-energization (see note F) K27/Q2 = Voltage measuring relay for normal supply line K27/Q2D = Auxiliary relay delayed on de-energization (see note F) K27/Q2E = Auxiliary relay delayed on energization (see note F) K51/Q1 = Overcurrent relay for emergency supply line K51/Q2 = Overcurrent relay for normal supply line K83 = Relay for the automatic changing-over M = Motor for opening the circuit-breaker and loading the closing springs of the circuit-breaker Q1 = C. breaker for emergency supply line Q2 = C. breaker for normal supply line Q61 = Miniature breaker with thermomagnetic overcurrent relay for isolation and protection of the auxiliary circuits S1,S2 = Contacts controlled by the motor operator cam S3 = Contact controlled by key lock device of the motor operating mechanism S43 = Two positions selector-switch to make the automatic changing-over operative SY/Q1 = Contact signalling Q1 c. breaker tripped through releases (see note B) SY/Q2 = Contact signalling Q2 c. breaker tripped through releases (see note B) TI/... = Current transformers feeding overcurrent relay XA7–XAB = Connectors for the auxiliary circuits of c. breaker YC = Closing release of the motor operating mechanism NOTES A) For the c. breakers auxiliary circuits see 1SDM000030R0.001 diagram. The accessories shown in following figures are mandatory: 11–23 (or 22 if overcurrent relay is supplied). B) In case of tripping of the overcurrent relay of one of c. breakers, for resetting set the S43 selector-switch in MAN. position, reset the tripped c. breakers manually and then set the S43 selector-switch in AUT. Position. C) Do not connect or isolate the c. breakers in withdrawable or plug-in version when the S43 selector-switch is in AUT. position. D) When putting the automatic changing-over in service, carry out the following operations: 1) set the S43 selector-switch in MAN. position, Q61 c. breaker must be open 2) close the Q61 c. breaker 3) wait for a period of time higher than the delay set on the K27/Q2 relay 4) set the S43 selector-switch in AUT. position E) The auxiliary voltage supplies shall be of safety type (not on network). F) The programming of delay times between receiving signals of voltage absence or presence and sending off the opening and closing controls to the c. breakers, must be carried out using the timers of K27/Q1D, K27/Q2D and K27/Q2E relays, considering that the c. breaker opening occurs in 1.5s while the closing occurs in 100 ms. In particular the delay of the K27/Q2D relay determines the delay time of the beginning of the changing-over sequence between the normal supply line and the emergency one, as regards the moment in which there is no normal supply voltage. This type of delay is useful for avoiding untimely changing-overs, which are caused by small voltage gaps. The delay of the K27/Q2E relay, on the other hand, determines the delay time of the beginning of the changing-over sequence between the emergency supply line and the normal one, as regards the moment in which the normal supply voltage returns. It is advisable to set this delay to high values, in order to avoid an unwanted changing-over when the normal supply line is unstable. The delay of the K27/Q1D relay is useful for avoiding untimely opening of the emergency line c. breaker, which are caused by small voltage gaps. G) The diagram indicates c. breakers with auxiliary circuits connected to XA7 and XAB connectors. For c. breakers without XA7 and XAB connectors see the circuits corresponding with 1SDM000030R0.001 diagram.			
MTX/E 320 - MTX/E 630 - MTX/E 1000		74279845 (1SDM00003SR0.001-L2S52)	GEWISS 6/6

