

Product Data Sheet GW68563


68 ACS Range



The distribution board for construction sites type Q-BOX are designed to withstand the effects of wear, impact and the stress caused by atmosph. They come in pre-wired versions fitted with interlocked socketoutlets (with or without a fuse-holder) up to 63A, or socket-outlets type IEC 309.. The wired versions are also equipped with accessories like the emergency push-button, lockable doors, stainless steel tear-proof cablefastening hooks, and built-in transportation handles on the upper part of the board. To ensure the best possible positioning on the construction site, 68 Q-BOX ACS boards can be surface-mounted, floor-mounted or fitted on poles.

Туре	Q-BOX 4 ACS	board type	Wired
Colour	Light blue	Outer dim. LxHxD (mm)	636x821x400
Weight (kg)	22	Accordance with Standards	EN 61439-4 (ACS)
Characteristics	UV resistance (EN 62208)	IP degree	IP55
Mechanical resistance	IK10	Glow wire test	650 °C
Thermo-pressure with ball	70 °C	Insulation class	
Power supply	Terminal block	No. of poles	3P+N+E
Power suppliable (kW)	17	Mains switch	RCBO 32A 4P 6 kA 0,03A - AC type
Circuits protection	MCB	No. socket outlets	4
Socket-outlet 2P+E 16A - IB	2	Socket-outlet 3P+E 16A - IB	2
Emergency push-button	Yes		

BEHAVIOUR WITH CHEMICAL AND ATMOSPHERIC AGENTS											
Saline solution	Acids		Bases		Solvents			Mineral	UV		
	Concentrated	Diluited	Concentrated	Diluited	Hexane	Benzol	Acetone	Ethyl alcohol	oil	rays	
Resistant	Limited resistance	R <mark>esista</mark> nt	Limited resistance	Resistant	Limited resistance	Limited resistance	Li <mark>mit</mark> ed resi <mark>stan</mark> ce	Resistant	Li <mark>mite</mark> d res <mark>istan</mark> ce	Resistant	



TECHNICAL SYMBOLOGY



STANDARDS/APPROVALS



GEWISS S.p.A. Via Domenico Bosatelli 1 24069 Cenate Sotto - Bergamo - Italy tel. +39 035 94 61 11 fax +39 035 94 69 09 www.gewiss.com sat@gewiss.com Last update 10/05/2025 Data, measures, designs and pictures are shown only as informative purposes, and could be changed without previous notice